



Pimpri Chinchwad Municipal Corporation
Fire Department
Date 25/02/2019

NO OBJECTION CERTIFICATE / FIRE SAFETY CERTIFICATE

Pandurang International English School (V.H.B.P. Pandurang Kate Pratishtan) Sr. No. 136/7/1, 136/7/2, 136/8, 135/4A, 135/3B, at Pimple Saudagar, Pune had applied for the fire Safety NOC of CBSE board school.

The fire brigade officer has visited the school inspected fire protection system installed at site and as per his technical remarks this NOC is being issued subject to compliance of following condition :

- 1) The entire fire fighting system installation installed at the site should be maintained in excellent working condition for fire emergency.
- 2) The fire extinguishers handling and operational training to be imparted to the teaching / non teaching / Security Staff of the school.
- 3) You will carry out refilling and testing of the fire extinguishers and maintain fire fighting system from competent person (Govt. Fire licensed Agency) and submit the certificate (B- Form) in writing every year along with the renewal application.
- 4) You will keep the static water tanks full for emergency.
- 5) Fire / emergency Evacuation Mock Drill should be carried out in the school once in every six months.
- 6) You will keep all passages and corridors free from any obstructions and combustible material.
- 7) " No smoking boards" " Emergency Exit" " Assembly Area " and " Emergency Contact Number Boards" of fire, Ambulance, Police, MSEB, shall be always displayed in school avoid / minimize fire / emergency situation/risk.
- 8) This NOC is issued only from the fire safety point of the view . It cannot be trusted for any other purposes . However necessary permission from the statutory authorities should be obtained .
- 9) All the rules, regulation and conditions of PCMC , from the time to time , shall be binding on you and any violation of these shall be viewed seriously .
- 10) Necessary 'B - Form' from Govt. Approved fire Licensed Agency towards the maintenance and operational working of the fire fighting system installed in building to be submitted to this fire office as per the Sec. 3 (3) of the fire Act. 2016, for every six months, in month of January to July failing of which the NOC to be treated as cancelled .
- 11) This school operational (Utility) fire NOC to issue with respect to the final fire NOC. No. Fire No- FSC/PCMC/45/2019, Date - 25/02/2019 fire dept. PCMC.
- 12) This fire NOC is valid up to date- 24/2/2022 and Renewal of these NOC should be done every year before above mentioned date.

Kaketa
Chairman

VHBP Pandurang Kate Pratishtan
Pimple Saudagar, Pune -27

J. K. D.
PRINCIPAL

P. K. International English School
Pimple Saudagar, Pune-411027

ghe
CHIEF FIRE OFFICER

Pimpri Chinchwad Municipal Corporation