



Pimpri Chinchwad Municipal Corporation

Pimpri, Pune - 411018.

Phone :- 020- 67331110/1120

Fax :- 020- 27425600

E-Mail :- commissioner@pcmcindia.gov.in

Web :- www.pcmcindia.gov.in

NO - ws/lab/2384/2026

Date - 28/03/2026

To

The Principal,

P K International English School,

Pimple Saudagar.

Subject: Water sample Potability Certificate.

Drinking water sample provided by P K International English School, Pimple Saudagar on Date: 27/03/2026 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /2381/2026 dated 28/03/2026 & ws /lab /2383/2026 dated 28/03/2026 the water Samples are safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44



PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

No-WS/LAB/2383/2026.

Date - 28 / 03 / 2026.

NAME - P.K International English School DATE OF EXAMINATION - 27 / 03 / 2026.

ADDRESS - Pimple Saudagar.

SOURCE -

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample	Nil	0/100ml	-	Potable.
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY



PIMPRI CHINCHWAD MUNICIPAL CORPORATION
(W/S) DIVISION

REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - P.K International English School.

ADDRESS - Pimple Saudagar.

SOURCE -

No-WS/LAB/2381/2026.

Date - 28 / 03 / 2026.

Date of Receipt - 27 / 03 / 2026.

Date of Examination - 27 / 03 / 2026.

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	1.55 NTU.		
2	pH	6.5 to 8.5	7.54		
3	Total Hardness (as CaCO ₃)	200 mg/lit	60 mg/lit.		
4	Chloride	250 mg/lit	16 mg/lit.		
5	Calcium	75 mg/lit	14.42 mg/lit.		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST

WATER TREATMENT PLANT, NIGDI, PCMC

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated: 30/03/2026

It is certified that an inspection team headed by Executive Engineer Water Dep.

(Name of Officers with designation) from Water Department PCMC PHED

inspected the P.K. International English School, So. No. 135, 136

(Name & Address of the school) on Pimple Saudagar 27/03/2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. W.S./Lab/2384/2026 dated 28/03/2026

of (PHED Lab) certified that

the P.K. International English School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 1 Year

Signature with Seal:

Name

Designation

Name & Address of the Office / Department : Water

To

V.H.B.P. Pandurang Kate Prashanthan's reporting PCMC
P.K. International English School,
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

