

FIRE SAFETY CERTIFICATE

APPENDIX - XII

No. FB52526D-1/73

Dated: 08-08-2025

Certified that the P.K.INTERNATIONAL ENGLISH SCHOOL {name of the Building or premises} at SR. NO. 135,136, PIMPLE SAUDAGAR, PUNE-411027 {address} comprised of One basement(s) and SIX {upper floors} owned/occupied by V.H.B.P. PANDURANG KATE PRATISHTHAN, PIMPLE SAUDAGAR, PUNE-27. {name of the institution} have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 29-07-2025 {date of inspection} in the presence of Principal - Prof. Dhanashree Sonawane {name and addresses of the Manager/ Secretary or his representative} and that the building/ premises is fit for occupancy up to classes I TO XII. (X/ XII) With effect from 08-08-2025 for a period of 1 year in accordance with rule and subject to compliance of specific conditions as appended:-

1. All sprinklers found working in good condition.
2. Pump Room is found working but need to be kept Clean & Dry.
3. Booster Pumps are in working conditions
- 4.

Issued on 08-08-2025 {date of issue} at Pune {place} by

*Strike out whichever is not applicable.

Signature with Seal: 

उप अग्निशमक अधिकारी

Name

अग्निशमक विभाग

Designation

पिंपरी चिंचवड महानगरपालिका

पिंपरी, पुणे-४११ ०१८.

Name & Address of Department V Office:

To

P.K.INTERNATIONAL ENGLISH SCHOOL
SR.NO.135,136 , PIMPLE SAUDAGAR,
PUNE 411027.

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to

(reasons to be recorded).

(Name and designation of the authorized signatory)

- The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.



Chairman

V.H.B.P. PANDURANG KATE PRATISHTHAN'S
Pimple Saudagar


PRINCIPAL

P. K. International English School
Pimple Saudagar, Pune-411 027